


RESTRICTED

TECHNICAL SPECIFICATION OF CHARGER M MODULE OF FIRE DETECTION SYSTEM - BNS SANGRAM

Ser	Particulars	Description
1.	Name of Item	Charger M
2.	Quantity	01 (One)
3.	Model/ Part No.	5100082
4.	PSU Input	28 VDC
5.	Operating Voltage Range	19-30 VDC
6.	Max. Output Current	8 A
7.	NTC Resistor	10 kΩ 2%, B=3977, 3×3
8.	GA Input Resistor	10 kΩ
9.	Operating Temperature Range	10 °C to +85 °C
10.	Name of Main Equipment	Addressable Fire Detection System
11.	Country of Origin	Sweden
12.	Country of Manufacture	Sweden
13.	Year of Manufacture	2023 or later
14.	Manufacturer's Name and Address	Consilium Marine & Safety AB; Fire & Gas Marine Division P.O. Box 8763 SE-402 76 GOTHENBURG, SWEDEN Tel: +46 31710 77 00, +46 31710 78 00, Fax: +46-31-710 78 00 Web: www.consilium.com, E-mail: Service: service@consilium.se Spares: spares@consilium.se
15.	Packing/labeling	To be packed and labeled for international shipping
16.	Warranty	At least 12 months from date of acceptance
17.	Pictu:	

RESTRICTED

Maidul Islam
18/08/24
M MAIDUL ISLAM
Commander BN
Electrical Officer
BNS SANGRAM